

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1281

Date : 30.9.2024

It is certified that an inspection team headed by Jai Narayan Mehra
Assistant Engineer (Name of Officers
with designation) from A.E.M. P.H.E.D City Sub Div. NAGAUR (Name of
Department/Office) inspected the ST. ANSELM Sr. Sec. School
NAGAUR (Name & Address of
the School) on 30.8.2024 and found that the ST. ANSELM Sr. Sec. School
NAGAUR (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal : [Signature]

Name :

Designation :

सहायक अभियन्ता
जन स्वास्थ्य अभियन्ता
सहायक अभियन्ता
नगर उपखण्ड-नागौर

जयनारायण मेहरा
सहायक अभि
P.H.E.D नगर उपखण्ड नागौर

To

ST. ANSELM Sr. Sec. School

NAGAUR

(Name & Address of the Institution)



Government of Rajasthan
Office of the Junior chemist
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY, NAGOUR
PHED Chouraha PHED Campus, Nagaur- 341001



Certificate No.: TC 12686

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Test Report No.: JC/NABL/CHE./24-25/ 561

Issue Date: 30-8-24

Issued to:
The Principal
St. Anselms Sr. Secondary School
Nagaur
Format No.: PHE/7.8.2/F-01

District: Nagaur
Block/City: Nagaur

Sample Code No.		NGR2024/21-0038		NABLCode No.(UID)		TC126862000000038F	
Customer Reference Letter No.		1		Source Description :		Tap Water	
Reference Date:		23.8.24		Sample / Source Location :		Campus St.Anselms school	
Sample received on dated :		23.8.24		Habitation/Ward No. :		Nagaur	
Sample Collected by :		Sh.Sanjay		Village/Colony/Nagar :		Nagaur	
Design. of Sample Collector:		-		Gram Panchayat/City Area :		Nagaur	
Latitude of Location		-		Sample Collected on Dated & Time :		23.8.24	
Longitude of Location		-		Date of Analysis Started :		27.8.24	
				Dated of Analysis Completed :		27.8.24	
Test Parameters		IS-10500:2012		References Method: Protocol Used		Test Values	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources				
1	pH	6.5 to 8.5	No relaxation	APHA, Edn. 24th, 4500-H+ B		7.89	
2	Total Alkalinity (as CaCO ₃) mg/l	200	600	APHA, Edn. 24th, 2320 B		50	
3	Total Hardness (as CaCO ₃) mg/l	200	600	APHA, Edn. 24th, 2340 C		60	
4	Calcium (as Ca) mg/l	75	200	APHA, Edn. 24th, 3500-Ca B		12	
5	Magnesium (as Mg) mg/l	30	100	APHA, Edn. 24th, 3500 Mg B		7.20	
6	Chloride (as Cl ⁻) mg/l	250	1000	APHA, Edn. 24th, 4500 Cl B		30	
7	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	APHA, Edn. 24th, 4500-NO ₃ B		3	
8	Fluoride (as F ⁻) mg/l	1.0	1.5	APHA, Edn. 24th, 4500- F C		0.14	
9	Conductivity µs/cm	-	-	APHA, Edn. 24th, 2510-B		245	
10	TDS (mg/l)	500	2000	APHA, Edition 24th, 2540-C		159	

Sample Analysed by

Result Checked by

Authorized Signatory

JLA/SLA/Jr. Chemist

SLA/Jr. Chemist

Junior Chemist, Nagaur

NOTE:

- This test report shall not be reproduce except in full, unless permission for the reproduction has been obtained from the Junior Chemist, PHED District Laboratory,
- This test report relates only to the samples/items submitted to the laboratory for test.
- The test report can't be used for any publicity or any legal purpose.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- Sampling related information is in bold letters given by the Engineer's/Customer's.**
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Telephone :

-----End of Test Report-----

E-mail: phediabnagaur@gmail.com



Public Health Engineering Department, Rajasthan
District Laboratory, Nagaur

Report of the Bacteriological Examination of Water

Date : 30/08/2024

To:
ST ANSELM SR SEC SCHOOL,
ST ANSELM SR SEC SCHOOL,
NAGOUR

District : NAGOUR

Sample Taker : ST ANSELM SR SEC
SCHOOL


Reference No : 1214, Dated : 23/08/2024
Date of Receipt : 23/08/2024
Date of Exam : 25/08/2024

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
1250	23/08/2024	Nagaur (M)	Tap	BEHINDE POLICE LINE KE PICHE NAGOUR	Nil	Nil	Satisfactory	Potable

No.Lab./Tech.(Bact)/2024-25/1250 561-30-8-24

PHED Laboratory Nagaur

30.8.24
फनिष्ठ रसायनज्ञ
जन स्वा० अभि० विभाग
प्रयोगशाला, नागौर
०डी०ओ० क्रोड 1038

E-CHALLAN (Manual Payment) Government Of Rajasthan Public Health Engineering Department		
Valid Upto:-	31/03/2025	Remitter's Copy for Dept
GRN :-	93529487	Date:- 23/08/2024 11:01:00 AM
BarCode:-		
Office Name:-	JR.CHEMIST, P.H.E.D., NAGAUR	
Location:-	NAGAUR	
Year:-	23/08/2024 To 31/08/2024	
Head(0215)	Amount	₹
0215-02-800-01-00-MISC. RECEIPT	600.00	
Discount :-		0.00
Total/Net Amount:-		600.00
Six Hundred Rupees and Zero Paise Only		
Payee Detail		
TIN/Actt. no./VehicleNo/TaxId/Lease No:-		
PAN No:-		
Remitter Name:- ST. ANSELM'S S SR.SEC. SCHOOL		
Address:- BEHINDE POLICE LINE KEPICHE nagaur,Rajasthan Nagaur- 341001		
Remarks: ONE SAMPLE CAMICALE ONE SAMPLE BACTERIOLOGICAL ANALYSIS		
23/08/2024 23/08/2024		
FOR USE IN RECEIVING BANK		
Cheque-DD-No.:		
Bank CIN No:-		
Bank SBI AnyWhere		

this challan in government account on T+1 basis